




Marine Corps Base Camp Lejeune  
Wastewater Collection System



**COLLECTION SYSTEM**  
126 Permitted Lift Stations

(Approximate Values)  
116 miles of gravity lines  
102 miles of force main lines

Legend:

- Wastewater Pipeline
- Wastewater Pumping Station
- Advanced WWTP Location

Marine Corps Base Camp Lejeune  
Advanced Wastewater Treatment Plant  
Permit No. NC0063029  
Wastewater Collection System  
Permit No. WQCS00015  
Annual Performance Report  
July 2015 – June 2016



**AWWTP Overall Performance**  
Overall operation of the Marine Corps Base Camp Lejeune (MCB CAMLEJ) AWWTP has met specifications.

**Summary of Violations**  
MCB CAMLEJ did not receive any violations for the 12 month period: July 2015 - June 2016.

**Wastewater Collection System - Public Reportable Spills**  
The North Carolina Clean Water Act of 1999, which became effective October 1, 1999, and as revised on September 20, 2014, requires that wastewater owners or operators must notify the public of wastewater spills. Wastewater owners or operators must issue a press release after a discharge to surface waters of 1,000 gallons within 24 hours of first knowledge of the spill by the owner/operator. The press release must be issued to "all print and electronic news media that provide general coverage in the county where the discharge occurred." For inadvertent discharges of wastewater reaching surface waters exceeding 15,000 gallons, a public notice is required in addition to a press release.

**During the monitoring period of record there were no reportable sewage overflows (spills).**

**Contacts**

For additional copies of this report, more information, or questions concerning the MCB CAMLEJ Wastewater Treatment System please contact the Deputy Director of Utilities for Water and Wastewater at 910-451-7190 ext. 223. A newspaper article announcing the availability of this report was recently published in the Base newspaper "The Globe."

For questions concerning the North Carolina Wastewater Annual Performance Program contact the Water Quality Permitting, Compliance and Expedited Permitting Unit of the NCDEQ, Division of Water Resources, Mr. Bob Sledge at 919-807-6398.

## Definitions

**mg/L (milligrams/Liter)** are the units of concentration used to express environmental measurements. 1 mg/L is equivalent to 1 part per million (ppm).

You can think of 1 ppm as 1 cent in \$10,000.

**Influent** - wastewater entering the treatment plant

**Effluent** - wastewater leaving the treatment plant


**BOD (Biochemical Oxygen Demand)** is a pollution indicator. It is a measurement of the dissolved oxygen needed by microorganisms to biologically degrade pollutants. The normal BOD test is conducted during a 5 day laboratory period and denoted BOD<sub>5</sub>. Raw domestic sewage typically has a BOD<sub>5</sub> of about 200 mg/L whereas a typical BOD<sub>5</sub> of unpolluted surface water would be less than 5 mg/L. If discharged to the environment, water with an elevated BOD could deplete (use up) the dissolved oxygen in rivers and streams due to the biological degradation of the pollutants by naturally occurring microorganisms. This can cause fish kills and septic conditions.

**TSS (Total Suspended Solids)** is a pollution indicator. It is simply a measurement of undissolved solids. Similar to BOD, raw domestic sewage typically has a TSS of about 200 mg/L. If discharged to the environment, elevated levels of TSS can produce sludge deposits and cause septic conditions.

**Ammonia Nitrogen (NH<sub>3</sub>-N)** represents the concentration of nitrogen bound in the ammonia form. Raw domestic sewage typically has an NH<sub>3</sub>-N of about 15 to 20 mg/L. If discharged to the environment, elevated levels of NH<sub>3</sub>-N can cause three problems. These include: (1) depletion of dissolved oxygen in rivers and streams because the biological degradation of ammonia is an oxygen consuming process, (2) impairment and death to fish and other aquatic organisms due to the direct toxicity of ammonia, and (3) increased growth of algae due to the nutrient effects of nitrogen.

**Phosphorus** is an essential nutrient for all biological growth. However, if discharged to the environment, elevated levels can cause excessive growth of algae and other aquatic plants. The subsequent decay of these plants can result in a depletion of dissolved oxygen.

## Treatment Plant Diagram



## GENERALIZED WASTEWATER TREATMENT PLANT (WWTP) PROCESS DESCRIPTION

The Camp Lejeune Advanced Waste Water Treatment Plant (AWWTP) is an advanced biological process that consists of three different microbial environments. The combined environments are called the A<sup>2</sup>O process for Anaerobic, Anoxic and Oxidic. These three zones cultivate a special mix of beneficial microorganisms that absorb phosphorus and convert chemically bound nitrogen to harmless and inert nitrogen gas. Residual phosphorus not absorbed by the microorganisms is removed by chemicals added by the WWTP's operations staff. Other microorganisms (primarily in the oxic zone) biologically degrade wastewater pollutants by using organic material as food and converting it to new microbes, carbon dioxide and water. All of the three A<sup>2</sup>O zones consist of mixed slurries of wastewater and microorganisms. After treatment, the water and microbes are separated by gravity settling in large tanks. The clean water is skimmed from the surface, filtered, disinfected with ultra-violet light and returned to the New River. The microbes are continuously collected from the bottom of the tanks and returned to the three A<sup>2</sup>O zones using recycle pumping systems. This recycling provides a continuous source of microbes to degrade incoming pollutants. As pollutants are removed, the microorganisms grow and multiply. This growth results in the production of excess microorganisms. These excess microbes are

continuously removed (a process called wasting) to maintain a consistent and optimal balance between available microbes and the amount of food (pollutants) entering the WWTP. The excess microorganisms (called residuals or biosolids) are treated at an elevated temperature (±150° F) to kill disease causing organisms, to reduce odors and for further treatment of bio-degradable pollutants. The treated residuals are applied to agriculture and forest areas for their beneficial nutrients and soil conditioning characteristics. The flow of water into and out of the WWTP is a continuous operation — the WWTP operates 24 hours per day and 365 days per year.

Descriptions of the WWTP processes are summarized below:

- 1 — Preliminary Treatment** is merely a screening process that removes large debris such as sticks, rags, grit and sand. The removal of these constituents protects downstream equipment.
- 2 — Primary Clarification** consists of large tanks where suspended solids settle to the bottom. The settled solids are transferred to the solids treatment process. In general this process removes about 50% of the TSS entering the WWTP influent. The remaining fraction is either degraded (solubilized) in the biological processes or removed in the WWTP's secondary clarifier.

- 3 — The Anaerobic Zone** is a mixed tank void of dissolved oxygen. The absence of all oxygen is conducive to the growth of special bacteria (*Acinetobacter*) that consume organic acids and release stored phosphorus in the anaerobic tank. However, these same organisms uptake high levels of phosphorus when they enter the aerobic (oxic) zone of the WWTP. Thus, the cycling of the microbes between the anaerobic and oxic environments is the mechanism responsible for enhanced phosphorus uptake. This cycling is accomplished by the normal flow of water and the recycle system that returns the microbes to the anaerobic zone after they have been oxygenated in the oxic zone of the WWTP. Phosphorus (an algae causing nutrient) is ultimately removed from the WWTP by wasting excess microbes after the oxygenated cycle and when stored phosphorus levels are greatest.

- 4 — The Anoxic Zone** consists of mixed tanks that have essentially no dissolved oxygen. However, these tanks do contain oxygen that is chemically bound to nitrogen in a molecule called nitrate (NO<sub>3</sub>-N). This nitrate nitrogen is a byproduct from the biological treatment of ammonia and is introduced to the anoxic zone through the recycle from the outlet of the aeration tank. In the absence of dissolved oxygen, bacteria in the anoxic zone break the chemical bond between the oxygen and nitrogen. The oxygen is used by the microbes to produce new bacteria, water and carbon dioxide. More importantly, the nitrogen (a nutrient responsible for the growth of excess algae) is removed from the water and released to the atmosphere as a harmless and inert gas.

- 5 — The Oxic (Aerobic) Zone** consists of mixed and oxygenated tanks. Oxygen is supplied from the atmosphere using mechanical agitators located on the surface of the tanks. In this process, aerobic (oxygen using) and other microorganisms perform the following:

**Reduce BOD:** This is the biological degradation of wastewater pollutants. Simply stated, microorganisms consume organic material for food and convert it to new microbes, carbon dioxide and water.

**Nitrify Ammonia:** This is the biochemical oxidation of ammonia nitrogen to the much more stable and benign form called nitrate nitrogen (NO<sub>3</sub>-N). The benign NO<sub>3</sub>-N can be biologically degraded to nitrogen gas when recycled to the anoxic zone of the WWTP.

**Uptake of Phosphorus:** The special bacteria (*Acinetobacter*) cultivated in the anaerobic zone absorb a significant amount of phosphorus in the aerobic tank. This absorbed phosphorus is ultimately removed from the water when excess microorganisms are wasted from the WWTP.

- 6 — The Post Aerobic Anoxic Zone** uses the same mechanisms as previously described to convert nitrate to nitrogen gas. This particular zone is simply another location to cultivate special microbes and provide an additional opportunity for these organisms to convert nitrate to inert nitrogen gas.

- 7 — The Second Stage Aeration Zone** consists of small aerated tanks. This particular zone is simply used to return dissolved oxygen to the water following the anoxic (oxygen free) process.

- 8 — Secondary Clarification** consists of large tanks where the suspended biosolids (microorganisms) are separated from the water; the biosolids simply settle to the bottom of the tank. As a general rule of thumb, approximately 97 to 98% of the biosolids entering the secondary clarifier are recycled back to the anaerobic zone so they can treat incoming waste products. About 2 to 3% of these "phosphorus enriched biosolids" are due to the growth of excess microbes and are wasted to the solids treatment process.

- 9 — Filtration** is a polishing process that removes the trace levels of suspended solids that do not settle in the secondary clarifier. This process employs a layer of sand that removes the solids by straining and adsorbing suspended material.

- 10 — The Reaeration Process** is a small aerated tank used to increase the level of dissolved oxygen in the treated water just before it is discharged. This helps maintain higher oxygen content in the New River in the vicinity of the WWTP's discharge line.

- 11 — Disinfection** is the final process in the WWTP. It is used to kill disease causing microorganisms. It is important to note that no chemicals are used in disinfection process at this WWTP — biological kills are accomplished using environmentally benign ultraviolet (UV) light.

- 12 — Solids Thickening** is used to remove some of the water from the slurry of waste biosolids. Thickening is used to reduce the volume of waste solids and increase the capacity of the WWTP's residuals processing tanks. As a general rule, thickening reduces the volume by about 65 to 75%.

- 13 — Solids Treatment** is used to kill disease causing organisms, reduce odors and for further treatment of the biodegradable pollutants in the biosolids. The process consists of mixed and aerated tanks operated at about ±150°F. The heat is generated internally from the biological decomposition of the biosolids by special bacteria that flourish in this type of environment. This process is similar to composting.

## AWWTP Permit Limits and Performance Data

Permit Limits on AWWTP Effluent		
Parameter	Monthly Average Limitation (mg/L)	
	April 1 to October 31	November 1 to March 31
BOD <sub>5</sub>	5	10
TSS	30	30
NH <sub>3</sub> -N	2	4
Phosphorus	0.5	1

Future projects and improvements projected include a wastewater nutrient removal study, identification of new land application sites, inflow and infiltration study, replacement of sand filter media, and the rebuilding of #4 clarifier, bar screens and channels.

### Volume of Wastewater Treated

Daily Average	4.58 million gallons/day
Total Gallons Treated for the Year	1.671 billion gallons

### Biosolids Production During the 12 Month Period

Gallons of Liquid containing 2.86% Solids	6,167,500
Dry Tons (Excluding Water)	734.67