DRINKING WATER ANALYSIS SUMMARY Voluntary Monitroing - Detected Contaminants

System: Hadnot Point

PWSID: 04-67-041

Start Date: 01 Jan 2022 End Date: 30 June 2022

Contaminants	Average	Unit of	Range		MCL	
		Measure	Low	High	IVICL	
Finished Drinking Water Detections						
Explosive Constituents						
Perchlorate	0.307	ug/L	ONLY DETECTION N/A		N/A	
Unit Descriptions						
Term	Definition					
ug/L	Micrograms per liter (ug/L) or parts per billion (ppb)					

NOTE: Comprehensive raw and finished water sampling was completed in July 2022 in lieu of May 2022 and will be reflected in the Annual Voluntary Monitoring Summary that will be distributed in June 2023.



PROGRAM (SWAP) RESULTS

The North Carolina Department of Environmental Quality (NCDEQ), Public Water Supply Section (PWSS), Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (wells) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP reports that include maps, background information, and a relative susceptibility rating of Higher, Moderate or Lower. The relative susceptibility rating of each source for the Hadnot Point Water Treatment System was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings based on the SWAP report completed on September 10, 2020 are summarized in the table below:

Hadnot Point				
Drinking Water Supply Wells				
Source Name	ource Name Susceptibility Rating			
585	Moderate			
595	Lower			
596	Lower			
606	Moderate			
607	Moderate			
611	Lower			
612	Lower			
614	Lower			
621	Moderate			
622	Moderate			
627	Moderate			
630	Lower			
632	Lower			
640	Moderate			
641	Higher			
652	Lower			
661	Moderate			
662	Lower			
663	Lower			
668	Lower			
669	Moderate			
684	Lower			
685	Moderate			
686	Lower			
688	Lower			
709	Moderate			
710	Moderate			
711	Moderate			
5186	Higher			

The complete SWAP report for the Hadnot Point Water Treatment System may be viewed on the web at:

http://www.ncwater.org/?page=600

In order to access his report you will need to enter either the system name or PWS ID. Both have been provided below. Please note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this website may differ from the results that are available at the time this report was prepared.

System Name: USMC Lejeune - Hadnot Point

PWS ID: 0467041




It is important to understand that a susceptibility rating of "Higher" does not imply poor water quality, only the system's potential to become contaminated by PCSs in the assessment area.

Hadnot Point Water Treatment Process

As the raw water enters the water treatment plant, sodium hypochlorite is added to protect against microbial contamination, and the water is placed into a storage reservoir. From the storage reservoir the water is pumped to a set of large, cone-shaped devices

called spiractors. The spiractors are used to soften the water by removing minerals. Lime is added at the bottom of the spiractors to aid the softening process. The water is then passed through a set of filters, which contain layers of sand and carbon, to remove particles through a process called filtration. Fluoride (to prevent tooth decay) is added to the water, and then the clean water is placed in a large storage tank called a reservoir. When water is needed by customers, it is pumped from the reservoirs and distributed throughout the Hadnot Point community water system.



WATER CONSERVATION

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? You can play a role in conserving water by becoming conscious of the amount of water your household is using and by looking for ways to use less whenever possible. It is not hard to conserve water. Small changes can make a big difference. Here are a few tips:

- ➤ Take short showers a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- ➤ Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- ➤ Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- ➤ Check every faucet in your home for leaks. Just a slow drip can waste 15-20 gallons a day.
- ➤ Check your toilets for leaks by putting a few drops of food coloring in the tank. Watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from an invisible toilet leak.
- ➤ Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- ➤ Water plants only when necessary and adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- ➤ Don't run the hose while washing your car. Use a bucket of water and a quick hose rinse at the end or wash vehicles at a carwash that recycles its water. Saves 150 gallons each time.

Teach your kids about water conservation to ensure a future generation that uses water wisely. Visit www.epa.gov/watersense for more information.

Remember, when you conserve water you also conserve energy!