

Start Date: 01/01/2013

End Date: 12/31/2013

DRINKING WATER ANALYSIS SUMMARYResults For: SDWA-INORGANICPUBLIC WATER SYSTEM FOR: HBPWSID: 04-67-043

Parameter	Measured Results	Unit of Measure	Qualifier	Location Code	Building Number	Sample Collection		Comments
						Date Collected	Time Collected	
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
Iron	1,100	ug/L			704	3/4/2013	11:10	
Manganese	18	ug/L			698	3/4/2013	12:40	
Nickel	0.80	ug/L	J		698	3/4/2013	12:40	
Cobalt	0.13	ug/L	J		698	3/4/2013	12:40	
Iron	140	ug/L			699	3/4/2013	14:28	
Manganese	5.3	ug/L	J		699	3/4/2013	14:28	
Nickel	1.2	ug/L			699	3/4/2013	14:28	
Thallium	0.15	ug/L	J		699	3/4/2013	14:28	
Iron	190	ug/L			701	3/4/2013	14:53	
Manganese	7.8	ug/L	J		701	3/4/2013	14:53	
Zinc	10	ug/L	J		701	3/4/2013	14:53	
Iron	1,200	ug/L			703	3/4/2013	10:45	
Iron	360	ug/L			698	3/4/2013	12:40	
Nickel	0.92	ug/L	J		703	3/4/2013	10:45	
Lead	0.37	ug/L			701	3/4/2013	14:53	
Lead	0.48	ug/L			704	3/4/2013	11:10	
Manganese	23	ug/L			704	3/4/2013	11:10	
Nickel	0.40	ug/L	J		704	3/4/2013	11:10	
Iron	1,000	ug/L			704-DUP	3/4/2013	11:10	
Manganese	23	ug/L			704-DUP	3/4/2013	11:10	
Nickel	0.53	ug/L	J		704-DUP	3/4/2013	11:10	
Iron	930	ug/L			705	3/4/2013	10:07	
Manganese	22	ug/L			705	3/4/2013	10:07	
Nickel	0.40	ug/L	J		705	3/4/2013	10:07	
Iron	920	ug/L			705-DUP	3/4/2013	10:07	
Manganese	22	ug/L			705-DUP	3/4/2013	10:07	
Nickel	0.49	ug/L	J		705-DUP	3/4/2013	10:07	
Manganese	53	ug/L			703	3/4/2013	10:45	
Iron	1,100	ug/L			647	3/4/2013	9:24	
Nickel	0.48	ug/L	J		701	3/4/2013	14:53	
Nickel	0.47	ug/L	J		647	3/4/2013	9:24	
Manganese	21	ug/L			647	3/4/2013	9:24	
Lead	0.19	ug/L	J		617	3/7/2013	12:00	
Iron	870	ug/L			617	3/7/2013	12:00	
Copper	6.9	ug/L	J		617	3/7/2013	12:00	
Manganese	53	ug/L			584	3/7/2013	12:32	
Manganese	55	ug/L	B		648	3/7/2013	9:55	
Selenium	0.65	ug/L	J		558	3/7/2013	11:41	
Manganese	49	ug/L			558	3/7/2013	11:41	
Manganese	26	ug/L			617	3/7/2013	12:00	

NOTE - This database contains information about MCB, Camp Lejeune's drinking water systems and raw water supply. It was developed only to assist the Base manage and maintain analytical data concerning chemicals detected in drinking water. While EMD has made every effort to ensure the completeness and accuracy of the database, some errors and omissions may remain. Therefore, the user should always refer to the original report to ensure maximum accuracy and completeness.

Start Date: 01/01/2013

End Date: 12/31/2013

DRINKING WATER ANALYSIS SUMMARYResults For: SDWA-INORGANICPUBLIC WATER SYSTEM FOR: HBPWSID: 04-67-043

Parameter	Measured Results	Unit of Measure	Qualifier	Location Code	Building Number	Sample Collection		Comments
						Date Collected	Time Collected	
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
Iron	1200	ug/L			558	3/7/2013	11:41	
Iron	1400	ug/L			584	3/7/2013	12:32	
Iron	830	ug/L			708	3/7/2013	10:33	
Manganese	23	ug/L			708	3/7/2013	10:33	
Selenium	0.97	ug/L	J		708	3/7/2013	10:33	
Iron	1,400	ug/L			LCH4009	3/7/2013	13:10	
Lead	0.19	ug/L	J		LCH4009	3/7/2013	13:10	
Manganese	32	ug/L			LCH4009	3/7/2013	13:10	
Selenium	0.65	ug/L	J		LCH4009	3/7/2013	13:10	
Lead	0.41	ug/L			558	3/7/2013	11:41	
Zinc	10	ug/L	J		648	3/7/2013	9:55	
Nickel	0.45	ug/L	J		558	3/7/2013	11:41	
Nickel	0.57	ug/L	J		648	3/7/2013	9:55	
Nickel	0.43	ug/L	J		617	3/7/2013	12:00	
Iron	480	ug/L			650	3/7/2013	10:12	
Manganese	21	ug/L	B		650	3/7/2013	10:12	
Lead	0.72	ug/L			648	3/7/2013	9:55	
Iron	4,000	ug/L			648	3/7/2013	9:55	
Copper	6.2	ug/L	J		648	3/7/2013	9:55	
Selenium	0.69	ug/L	J		619	3/7/2013	10:50	
Iron	3,100	ug/L			618	3/7/2013	11:08	
Manganese	41	ug/L			619	3/7/2013	10:50	
Manganese	26	ug/L			617-DUP	3/7/2013	12:15	
Manganese	76	ug/L			618	3/7/2013	11:08	
Nickel	0.58	ug/L	J		618	3/7/2013	11:08	
Selenium	1.5	ug/L	J		618	3/7/2013	11:08	
Iron	1,300	ug/L			619	3/7/2013	10:50	
Iron	730	ug/L			617-DUP	3/7/2013	12:15	
Nickel	0.68	ug/L	J		648	7/22/2013	10:40	
Nickel	0.89	ug/L	J		647	7/22/2013	9:20	
Selenium	0.71	ug/L			648	7/22/2013	10:40	
Lead	0.25	ug/L	J		705	7/22/2013	10:00	
Iron	3100	ug/L			648	7/22/2013	10:40	
Zinc	170	ug/L			705	7/22/2013	10:00	
Selenium	1.0	ug/L	J		705	7/22/2013	10:00	
Nickel	0.46	ug/L	J		705	7/22/2013	10:00	
Manganese	27	ug/L			705	7/22/2013	10:00	
Iron	1500	ug/L			705	7/22/2013	10:00	
Cobalt	0.13	ug/L	J		647	7/22/2013	9:20	
Chloride	14	mg/L			647	7/22/2013	9:20	

NOTE - This database contains information about MCB, Camp Lejeune's drinking water systems and raw water supply. It was developed only to assist the Base manage and maintain analytical data concerning chemicals detected in drinking water. While EMD has made every effort to ensure the completeness and accuracy of the database, some errors and omissions may remain. Therefore, the user should always refer to the original report to ensure maximum accuracy and completeness.

Start Date: 01/01/2013

End Date: 12/31/2013

DRINKING WATER ANALYSIS SUMMARYResults For: SDWA-INORGANICPUBLIC WATER SYSTEM FOR: HBPWSID: 04-67-043

Parameter	Measured Results	Unit of Measure	Qualifier	Location Code	Building Number	Sample Collection		Comments
						Date Collected	Time Collected	
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
Iron	230	ug/L			647	7/22/2013	9:20	
Selenium	1.3	ug/L	J		647	7/22/2013	9:20	
Manganese	39	ug/L			647	7/22/2013	9:20	
Lead	0.37	ug/L			647	7/22/2013	9:20	
Chloride	20	mg/L			648	7/22/2013	10:40	
Manganese	43	ug/L			648	7/22/2013	10:40	
Zinc	1000	ug/L			647	7/22/2013	9:20	
Selenium	1.1	ug/L	J		558	7/22/2013	13:05	
Selenium	0.64	ug/L	J		618	7/22/2013	12:20	
Chloride	7.5	mg/L			618	7/22/2013	12:20	
Cobalt	0.15	ug/L	J		618	7/22/2013	12:20	
Iron	1200	ug/L			557	7/22/2013	12:43	
Lead	0.28	ug/L	J		557	7/22/2013	12:43	
Manganese	48	ug/L			557	7/22/2013	12:43	
Nickel	0.47	ug/L	J		557	7/22/2013	12:43	
Selenium	0.90	ug/L	J		557	7/22/2013	12:43	
Nickel	0.90	ug/L	J		618	7/22/2013	12:20	
Manganese	47	ug/L			558	7/22/2013	13:05	
Iron	900	ug/L			558	7/22/2013	13:05	
Chloride	9.6	mg/L			558	7/22/2013	13:05	
Iron	2100	ug/L			617	7/22/2013	13:34	
Manganese	49	ug/L			617	7/22/2013	13:34	
Nickel	0.46	ug/L	J		617	7/22/2013	13:34	
Selenium	1.1	ug/L	J		617	7/22/2013	13:34	
Chloride	9.0	mg/L			617	7/22/2013	13:34	
Iron	450	ug/L			650	7/22/2013	11:00	
Chloride	9.2	mg/L			705	7/22/2013	10:00	
Chloride	7.9	mg/L			557	7/22/2013	12:43	
Manganese	20	ug/L			650	7/22/2013	11:00	
Nickel	0.58	ug/L	J		558	7/22/2013	13:05	
Chloride	12	mg/L			650	7/22/2013	11:00	
Iron	1200	ug/L			708	7/22/2013	11:20	
Lead	0.4	ug/L			708	7/22/2013	11:20	
Manganese	31	ug/L			708	7/22/2013	11:20	
Nickel	0.54	ug/L	J		708	7/22/2013	11:20	
Manganese	140	ug/L			618	7/22/2013	12:20	
Zinc	120	ug/L			708	7/22/2013	11:20	
Chloride	11	mg/L			708	7/22/2013	11:20	
Iron	1400	ug/L			619	7/22/2013	11:42	
Lead	0.13	ug/L	J		619	7/22/2013	11:42	

NOTE - This database contains information about MCB, Camp Lejeune's drinking water systems and raw water supply. It was developed only to assist the Base manage and maintain analytical data concerning chemicals detected in drinking water. While EMD has made every effort to ensure the completeness and accuracy of the database, some errors and omissions may remain. Therefore, the user should always refer to the original report to ensure maximum accuracy and completeness.

Start Date: 01/01/2013

End Date: 12/31/2013

DRINKING WATER ANALYSIS SUMMARYResults For: SDWA-INORGANICPUBLIC WATER SYSTEM FOR: HBPWSID: 04-67-043

Parameter	Measured Results	Unit of Measure	Qualifier	Location Code	Building Number	Sample Collection		Comments
						Date Collected	Time Collected	
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
Manganese	50	ug/L			619	7/22/2013	11:42	
Nickel	0.68	ug/L	J		619	7/22/2013	11:42	
Selenium	0.81	ug/L	J		619	7/22/2013	11:42	
Chloride	8.4	mg/L			619	7/22/2013	11:42	
Iron	7600	ug/L			618	7/22/2013	12:20	
Lead	0.13	ug/L	J		618	7/22/2013	12:20	
Nickel	0.44	ug/L	J		650	7/22/2013	11:00	
Lead	0.10	ug/L	J		584	7/23/2013	8:17	
Chloride	8.6	mg/L			584	7/23/2013	8:17	
Selenium	1.4	ug/L	J		584	7/23/2013	8:17	
Iron	1300	ug/L			584	7/23/2013	8:17	
Manganese	51	ug/L			584	7/23/2013	8:17	
Nickel	0.47	ug/L	J		584	7/23/2013	8:17	
Chloride	10	mg/L			701	7/24/2013	10:49	
Lead	0.069	ug/L	J		699	7/24/2013	10:32	
Manganese	5.5	ug/L	J		699	7/24/2013	10:32	
Nickel	0.95	ug/L	J		699	7/24/2013	10:32	
Selenium	0.70	ug/L	J		699	7/24/2013	10:32	
Thallium	0.14	ug/L	J		699	7/24/2013	10:32	
Chloride	8.5	mg/L			699	7/24/2013	10:32	
Iron	220	ug/L			701	7/24/2013	10:49	
Lead	0.19	ug/L	J		701	7/24/2013	10:49	
Zinc	8.5	ug/L	J		701	7/24/2013	10:49	
Iron	1300	ug/L			LCH4009	7/24/2013	11:49	
Lead	0.42	ug/L			LCH4009	7/24/2013	11:49	
Manganese	24	ug/L			LCH4009	7/24/2013	11:49	
Iron	2400	ug/L			703	7/24/2013	8:11	
Selenium	1.1	ug/L	J		LCH4009	7/24/2013	11:49	
Iron	360	ug/L			699	7/24/2013	10:32	
Zinc	9.0	ug/L	J		LCH4009	7/24/2013	11:49	
Chloride	8.2	mg/L			LCH4009	7/24/2013	11:49	
Manganese	8.1	ug/L	J		701	7/24/2013	10:49	
Nickel	1.3	ug/L			703	7/24/2013	8:11	
Manganese	64	ug/L			703	7/24/2013	8:11	
Lead	0.094	ug/L	J		703	7/24/2013	8:11	
Chloride	6.8	mg/L			698	7/24/2013	10:10	
Selenium	1.2	ug/L	J		703	7/24/2013	8:11	
Zinc	110	ug/L			703	7/24/2013	8:11	
Chloride	8.3	mg/L			703	7/24/2013	8:11	
Iron	980	ug/L			704	7/24/2013	11:16	

NOTE - This database contains information about MCB, Camp Lejeune's drinking water systems and raw water supply. It was developed only to assist the Base manage and maintain analytical data concerning chemicals detected in drinking water. While EMD has made every effort to ensure the completeness and accuracy of the database, some errors and omissions may remain. Therefore, the user should always refer to the original report to ensure maximum accuracy and completeness.

Start Date: 01/01/2013

End Date: 12/31/2013

DRINKING WATER ANALYSIS SUMMARYResults For: SDWA-INORGANICPUBLIC WATER SYSTEM FOR: HBPWSID: 04-67-043

Parameter	Measured Results	Unit of Measure	Qualifier	Location Code	Building Number	Sample Collection		Comments
						Date Collected	Time Collected	
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
Lead	0.077	ug/L	J		704	7/24/2013	11:16	
Manganese	22	ug/L			704	7/24/2013	11:16	
Nickel	0.47	ug/L	J		704	7/24/2013	11:16	
Zinc	15	ug/L	J		704	7/24/2013	11:16	
Chloride	8.0	mg/L			704	7/24/2013	11:16	
Iron	330	ug/L			698	7/24/2013	10:10	
Manganese	17	ug/L			698	7/24/2013	10:10	
Nickel	0.59	ug/L	J		698	7/24/2013	10:10	
Selenium	0.63	ug/L	J		698	7/24/2013	10:10	
Fluoride	0.6	mg/L		300	670	8/6/2013	9:25	
Iron	0.121	mg/L		300	670	8/6/2013	9:25	
Iron	0.222	mg/L			PP2219	8/15/2013	14:45	KLINE RESIDENCE
Fluoride	0.7	mg/L			PP2219	8/15/2013	14:45	KLINE RESIDENCE
Manganese	1.97	mg/L		985	PP2405	8/18/2013	1:00	CLOYD HOUSE
Lead	0.030	mg/L		985	PP2405	8/18/2013	1:00	CLOYD HOUSE
Iron	103	mg/L		985	PP2405	8/18/2013	1:00	CLOYD HOUSE
Copper	0.215	mg/L		985	PP2405	8/18/2013	1:00	CLOYD HOUSE
Fluoride	0.2	mg/L			TT1236	9/25/2013	14:00	1236 HARVEY CT
Iron	0.225	mg/L			TT1236	9/25/2013	14:00	1236 HARVEY CT
Manganese	NA	mg/L	Not Analyze		TT1236	9/25/2013	14:00	1236 HARVEY CT
Iron	14.2	mg/L			M305	9/26/2013	15:05	NEAR FIRE STATION
Fluoride	0.2	mg/L			M305	9/26/2013	15:05	NEAR FIRE STATION
Manganese	0.339	mg/L			M305	9/26/2013	15:05	NEAR FIRE STATION

NOTE - This database contains information about MCB, Camp Lejeune's drinking water systems and raw water supply. It was developed only to assist the Base manage and maintain analytical data concerning chemicals detected in drinking water. While EMD has made every effort to ensure the completeness and accuracy of the database, some errors and omissions may remain. Therefore, the user should always refer to the original report to ensure maximum accuracy and completeness.