

Start Date: 01/01/2013
 End Date: 12/31/2013

DRINKING WATER ANALYSIS SUMMARY

Results For: UCMR3

PUBLIC WATER SYSTEM FOR: HB

PWSID: 04-67-043

Parameter	Measured Results	Unit of Measure	Qualifier	Location Code	Building Number	Sample Collection		Comments
						Date Collected	Time Collected	
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
Chlorate-UCMR3	130	ug/L		300	670	3/13/2013	8:30	METHOD 218.7/300.1/200.8
Hexavalent Chromium [Cr+6]-UCMR3	0.12	ug/L		392	M19	3/13/2013	9:08	METHOD 218.7/300.1/200.8
Chlorate-UCMR3	150	ug/L		392	M19	3/13/2013	9:08	METHOD 218.7/300.1/200.8
Strontium-UCMR3	150	ug/L		392	M19	3/13/2013	9:08	METHOD 218.7/300.1/200.8
Hexavalent Chromium [Cr+6]-UCMR3	0.14	ug/L		300	670	3/13/2013	8:30	METHOD 218.7/300.1/200.8
Strontium-UCMR3	130	ug/L		300	670	5/21/2013	10:31	METHOD 218.7/300.1/200.8
Strontium-UCMR3	160	ug/L		392	M19	8/19/2013	13:46	
Hexavalent Chromium [Cr+6]-UCMR3	0.10	ug/L		300	670	8/19/2013	13:12	
Chlorate-UCMR3	570	ug/L		300	670	8/19/2013	13:12	
Strontium-UCMR3	150	ug/L		300	670	8/19/2013	13:12	
Hexavalent Chromium [Cr+6]-UCMR3	0.088	ug/L		392	M19	8/19/2013	13:46	
Chlorate-UCMR3	480	ug/L		392	M19	8/19/2013	13:46	

NOTE – This database contains information about MCB, Camp Lejeune’s drinking water systems and raw water supply. It was developed only to assist the Base manage and maintain analytical data concerning chemicals detected in drinking water. While EMD has made every effort to ensure the completeness and accuracy of the database, some errors and omissions may remain. Therefore, the user should always refer to the original report to ensure maximum accuracy and completeness.